



METAL HALIDE LUMINAIRE

METAL HALIDE FIXTURE SHALL HAVE BALLAST CLASS "H" INSULATED, -20°F STARTING, 60 HZ REGULATED HIGH POWER FACTOR TYPE. UNIT SHALL BE U.L. 57 LISTED AS "SUITABLE FOR WET LOCATIONS" AND 55° AMBIENT OPERATION. ENCLOSED AND GASKETED UNIT SHALL BE FURNISHED WITH A THERMAL SHOCK-AND IMPACT-RESISTANT GLASS REFRACTOR, PRODUCING A TYPE ASSEMETRICAL DISTRIBUTION. REFRACTOR TO BE FURNISHED WITH WIRE GUARD.

FURNISH WITH 150 WATT, QUARTZ LAMP STANDBY SYSTEM - ON WHEN POWER IS RESTORED: OFF WHEN H.I.D. LAMP RESTRIKES. FURNISH WITH RIGID CONDUIT STEM HANGERS.

LAMP
BALLAST

11-13-88
MH-4

1-175 WATT CLEAR METAL HALIDE
BT-28
PEAK LEAD AUTO TRANSFORMER