



HPS – LUMINAIRE

THE LUMINAIRE SHALL CONSIST OF A REAR DIE-CAST BACK HOUSING WHICH ENCLOSES THE BALLAST, LAMP SOCKET, AND ALUMINUM REFLECTOR; AND A THERMAL SHOCK-RESISTANT PRIMASTIC GLASS REFLECTOR. UNITS SHALL BE PREWIRED AND EQUIPPED TO BE WALL MOUNTED (OR POLE) DIRECTLY ON CONDUIT FOR SURFACE WIRING TO CONDUIT OR TO A RECESSED OUTLET BOX, AND SHALL REQUIRE NO TOOLS FOR LAMP REPLACEMENT. THE UNIT SHALL BE U.L. LISTED AS "SUITABLE FOR WET LOCATIONS". PROVIDE FIXTURE WITH PHOTOMETRIC OUTPUT EQUAL TO OR GREATER THAN THE DISTRIBUTION PATTERN SHOWN BELOW.

LAMP VOLTAGE AS SHOWN ON DRAWINGS
BALLAST – REGULATOR

250W HPS LU250/BU

HOLOPHANE

HPS-2

