

Priority list
SUPPORT WATER TENDER INSPECTION FORM
Attach copy to OF-296

Complement Requirements	Required:
1 –Programmable radio w/ cloning cables or ability to program	
Spray Bar or equivalent – Pump or PTO and/or Gravity on Front and/or Rear	
1 each 1½ inch nozzle NH – combination; fog/straight stream (plastic or metal)	
1 each 1½ inch NH female to 1 inch NPSH male reducer	
20 feet suction hose (minimum) with strainer or screened foot valve	
1 each Shovel, size 0 or 1	
1 each Pulaski	
1 each Spanner wrench, combination 1½ to 2½	
1 each Adjustable hydrant wrench	
2 adapters, 1½ inches NPSH female to 1½ inches NH male	
2 adapters, ¼ turn to 1½ inches NH (1 female and 1 male ea.)	
2 adapters, 1½ inches NH female to 1½ inches NPSH male	
2 reducers, 2½ inches NH female to 1½ inches NH male	
1 double male, 1½ inches NH	
1 double female, 1½ inches NH	
1 gated wye, 1½ inches NH	
1 Fire Hose Clamp -2 1/2 inches	
1 first aid kit (5 person)	
Reflectors (1 set of 3)	
1 EACH FIRE EXTINGUISHER (10BC or better)	
2 each Wheel chocks (NFPA 1906 standards)	
Fuel to operate pump and engine for 12 hours (minimum 5 gallons)	
2 each, portable hand lights	
100 feet of 1½ inches cotton/synthetic hose, NH thread	
50 feet of 2½ inches cotton/synthetic hose, NH thread	
Discharge outlets: 2 each 1½ inches NH thread	
Discharge outlet, 1 each 2½ NH thread	
FIRE SHELTER, NFPA APPROVED*	
2 CANTEEN-1QT. MINIMUM	
BOOTS, LEATHER LACE UP WITH LUG SOLE, 8” TOPS	
HARDHAT (w/chin strap), PLASTIC 1, OSHA APPROVED	
GLOVES, LEATHER, 1 PAIR	
EYE PROTECTION: One Pair (Meets Standards ANSI Z87 Latest Edition)	
FLAME RESISTANT CLOTHING (shirt & trousers, 2 sets for operator)	
Equipment complement manifest	
Two Copies of complete agreement	
1 Water Tender Operator (WTOP) listed on copy of agreement	

Pre-use _____ Release _____ COMMENTS ON BACK? YES _____ NO _____

Inspector(print): _____ Date: _____

Contractor Signature: _____ Date: _____