

CHECKLIST FOR POTABLE WATER TRUCK

<p>TANK MARKINGS</p> <ul style="list-style-type: none"> • 4 inch high or better, labeled “POTABLE or FOR DRINKING WATER USE ONLY”. • CAPACITY OF TANK (in gallons) Displayed on both sides of tank or cab doors in lettering at least 2 inches in height • NAME and ADDRESS of the Contractor displayed on both sides of the tank or on both cab doors in lettering at least 2 inches high 	
<p>TANK OPENINGS</p> <ul style="list-style-type: none"> • Hatches and other openings completely covered and sealed and equipped with security locks 	
<p>WATER INLETS AND OUTLETS</p> <ul style="list-style-type: none"> • Equipped with threaded or clamped caps, tethered to the ports with chain or cable. Caps in place except when water being discharged or loaded. 	
<p>VENTS</p> <ul style="list-style-type: none"> • Downward facing, protected with a non-toxic, non-absorbent material 	
<p>DRAIN</p> <ul style="list-style-type: none"> • A bottom drain shall be provided to facilitate complete discharge of water during sanitation procedures 	
<p>TANK FILLING MECHANISMS:</p> <ul style="list-style-type: none"> • Pipes and fittings conveying potable water to any fixture, apparatus or equipment shall be installed in such a way that backflow is prevented. • Overhead filler pipe shall not intrude into the tank further than two diameters of the filling pipe. When not being used for filling, pipe shall be capped. • Approved backflow prevention device, such as double check valves on direct filling connection to the tank 	
<p>PUMP</p> <ul style="list-style-type: none"> • Readily disassembled to demonstrate condition of impeller and impeller chamber • Internal pump surfaces must be smooth, non-porous and corrosion resistant • Food grade seals and lubricants are required 	
<p>CERTIFICATE</p> <ul style="list-style-type: none"> • Seal, sticker or certificate issued by State or local authority indicating that the tank has been inspected, certified and found to be in compliance with state requirements 	
<p>HOSES</p> <ul style="list-style-type: none"> • Food grade or suitable for potable water • Labeled as “POTABLE WATER” • Capped when not in use 	
<p>ACCESSIBILITY</p> <ul style="list-style-type: none"> • (7) seven ¾ inch faucets • (1) one 1 inch faucet (above faucets and this faucet evenly spaced on 1 ½ inch pipe) • All materials used for plumbing must be made of food grade materials or acceptable metal (Brass, Aluminum, Stainless steel or copper) 	

Pre-use ___ Release ___ COMMENTS ON BACK? YES ___ NO ___

Inspector (print): _____ Date: _____

Contractor Signature: _____ Date: _____